

Analysis of Systems Code Results

J. F. Lyon, ORNL

ARIES Meeting

Nov. 17, 2005



Motivation for This Talk

- **Questions regarding costing in code**
 - Farrokh: “in ISW paper, CS device has 60% more weight than ARIES-AT and a lower COE”
 - NCSX CS: mass = 12,102 tonnes (15% more)
COE = 55.7 mills/kW-hr (1992)
 - ARIES-AT: mass = 10,495 tonnes
COE = 56.6 mills/kW-hr (1992)
- **Would like to compare the ARIES-CS cost machine parameters and cost numbers with our older designs**
 - i.e., ARIES-AT and ARIES-RS

Topics

- **NCSX-ARE reference case parameters**
- **Component volume formulas and values**
 - blanket/shield/manifold/vacuum vessel
 - coils and associated structure
- **Cost and density database used**
- **Detailed component masses and costs**
 - blanket/shield/manifold/vacuum vessel
 - coils and associated structure
- **Costing for each subaccount and comparison with earlier ARIES reactor cases**

Plasma and Coil Parameters


Configuration	MHH2 K14LA	NCSX ARE
# of Period	2	3
Plasma Aspect Ratio	2.66	4.55
Plasma β @ optimization (%)	5.00	4.06
Plasma Current, I/R-B (MA/m-T)	0.201	0.072
Normalized Plasma Volume, Vol/R ³	2.793	0.950
Normalized Plasma Surface Area/R ²	18.547	11.780
$\iota(s = 0)$	0.33	0.42
$\iota(s = 0.67)$	0.48	0.64
$\iota(s = 1.0)$	0.58	0.66
Epsilon effective (%), max	~0.8	~0.6
Alpha energy loss (%), model calc.	~5	~10
# of Coil Type	4	3
# Coils/Period	8	6
Total # of Coils	16	18
Coil Aspect Ratio: $R/\Delta_{\min}$ (coil-plasma)	5.55	5.89
Coil Separation Ratio: $R/\Delta_{\min}$ (coil-coil)	10.33	10.03

Plasma and Coil Parameters


Configuration	MHH2 K14LA	NCSX ARE
Normalized Max. Coil Current: $I/R-B$ (MA/m-T)	0.316	0.306
Normalized Coil Lengths: L/R; Coil 1	6.14	4.77
Coil 2	5.83	5.08
Coil 3	5.52	5.14
Coil 4	5.25	-----
Normalized Winding Surface Area: $Area/R^2$	40.1	27.0
Normalized Max Field in Coils: $B_{max}/B(0)$ 0.20 m x 0.20 m	4.27	4.02
0.30 m x 0.30 m	2.69	2.63
0.40 m x 0.40 m	1.94	2.10
0.50 m x 0.50 m	1.72	1.85
0.60 m x 0.60 m	1.60	1.70
0.80 m x 0.80 m	1.46	1.59

Reference Plasma and Coil Configurations

Key Configuration Properties	ARE	LA14
Plasma aspect ratio $A_p = \langle R \rangle / \langle a \rangle$	4.55	2.66
Plasma surface area / $\langle R \rangle^2$	11.78	18.55
Minimum pl-coil dist. ratio $A_\Delta = \langle R \rangle / \Delta_{\min}$	5.89	5.55
Minimum coil-coil dist. ratio $\langle R \rangle / (c-c)$	10.03	10.33
Total coil length / $\langle R \rangle$	89.3	91.0
Coil winding surface / $\langle R \rangle^2$	40.1	27.0
$B_{\max} / \langle B_{\text{axis}} \rangle$, 0.3 m x 0.3 m coil pack	2.63	2.69



NCSX-ARE




MHH2-LA14

NCSX-ARE example

- For 5 MW/m² max. on wall, $\langle R \rangle_{\min} = 6.85$ m
 — $(11.78 R^2)(1+0.05/1.522)(5/1.52) = 18.78.6$ MW
- For coil depth = 0.184 m, $\langle R \rangle_{\min} = 6.61$ m
 — $R = 5.89 \times (0.05 + 0.038 + 0.17 + 0.05 + 0.38 + 0.02 + 0.28 + 0.02 + 0.022 + 0.184/2)$
- Code gives $\langle R \rangle = 6.93$ m for $\langle \beta \rangle = 5\%$

Code Minimizes COE

- Since radial thicknesses of most components are approx. fixed, volumes (and costs) $\sim$ areas $\sim R^2$, so code minimizes $\langle R_{\text{axis}} \rangle$
- $\langle R_{\text{axis}} \rangle$ set by *larger* of $(5/p_{\text{wall,max}})^{1/2}$ or $A_{\Delta} D$
 - fixes l_{coil} , L_{coil} , coil-coil spacing and hence coil elongation
- Maximum half-coil-radial-depth set by space between vacuum vessel and coil winding surface
 - $\Rightarrow$ minimize cost by using maximum coil thickness
 - j_{coil} and B_{max} decrease, cost decreases faster than coil volume (thickness) increases




NCSX-ARE Reference Parameters

- **Reactor Parameters**


- Electric Power = **1 GW**
- $\langle R \rangle / \langle R \rangle_{\min} = \mathbf{1.000}$
- max. neutron wall load **4.89 MW/m² (<5 MW/m²)**
 - $\langle R \rangle$ only 1% larger than $p_{n,wall}$ limit
- max. magnetic field at coil **$B_{\max} = 14.03$ T (<16 T)**
- current density **107.6 MA/m², $j_{\text{coil}}/j_{\max} = 1.00$**
- **port width 3.64 m & 2.36 m (>2 m)**
- average plasma density **4.59 x 10²⁰/m²,**
 $\langle n \rangle / 2n_{\text{Sudo}} = 1.00$
- ave. major radius **$\langle R_{\text{axis}} \rangle = 6.93$ m**
- ave. field on axis **$\langle B_{\text{axis}} \rangle = 6.28$ T**
- coil pack dimensions **0.184 m x 0.671 m**
- **Cost of Electricity 55.7 mills/kW-hr (1992 \$)**

Radial/Toroidal Cross Section



- Shield thickness is corrected for $\ln(p_{n,wall})$ term in code

Calculation of Volumes



- volume = mid-radius surface area (scaled radially from plasma surface area) x thickness
 - can shift to mid-radius normalized from CAD calculation when redone for $\langle R \rangle \sim 7$ m and can interpolate from $\langle R \rangle = 8.25$ value
- e.g., for FS shield, **volume** = [plasma surface area] x $(\langle a \rangle + 5 + 63 + 18/2)/\langle a \rangle \times 18 = [11.78 \times \langle R \rangle^2] \times (\langle a \rangle + 77)/\langle a \rangle \times 18 = 153.2 \text{ m}^3$
- **mass** = $153.2 \times 7.02 = 1075 \text{ t}$; **cost** = $153.2 \times 222.69 = 34.11 \text{ M\$}$
- code: $\text{vol} = 160.9 \text{ m}^3$, $\text{mass} = 1129 \text{ t}$, $\text{cost} = 35.7 \text{ M\$}$ with $\ln(p_{\text{wall}})$ term

Calculation of Coil-Associated Volumes

- **Coil winding pack (NCSX-ARE example)**
 - volume = length x cross section = 35.11 m³
 - length = $6(4.77 + 5.08 + 5.15)R = 90R = 622.96$ m
 - cross section = $(R/10.03 - 0.02)\text{depth}_{\text{coil}}$ or $I_{\text{coil}}/j_{\text{coil}} = (0.306RB)/j_{\text{coil}}$
 - coil winding surface = $27.0R^2 = R\langle a_{\text{coil}} \rangle [\text{plasma surface}]/(R\langle a \rangle)$,
so $\langle a_{\text{coil}} \rangle = (27/11.78)\langle a \rangle = 2.29R/4.55 = 0.504R$
- **Need to correct for thickness ($\sim B^2R^2$) & area of mid surface ($\langle R_{\text{axis}} \rangle$, r_{mid} , cumulative thickness corrections)**
 - Wang and Williamson used $\langle R \rangle = 8.25$ m, $\langle B \rangle = 5.3$ T
 - Bromberg used $\langle R \rangle = 6.73$ m, $\langle B \rangle = 6.2$ T
 - code has $\langle R \rangle = 6.93$ m, $\langle B \rangle = 6.28$ T
 - B^2R^2 correction = 0.99 (Wang, Williamson), 1.09 (Bromberg)
- **Used NCSX-ARE and corrected Bromberg values so far; need to decide on best approach**

D. Williamson's 3-D Model (*before* corrections)

Shell region
($t = 60$ cm)

Strongback region
($t = 120$ cm)

Center (bucking
cylinder region
($t = 200$ cm)

Coil Structure Surface Area (Field Period)




Inboard Region (Bucking Cylinder)	198.4
Strongback	33.1
Shell	165.3
Outboard Region	410.4
Strongback	45.0
Shell	365.4
Openings	
~1/3 of outboard shell area	- 120.6
Total	488.2

Coil-Associated Thicknesses

- **Strongback behind coils:**
 - Bromberg: thickness = 49-61 cm (average = 58.8 cm) ==> 64.0 cm
 - Wang: thickness ~ 65 cm ==> 64.4 cm
 - Williamson: thickness = 120 cm x 3/8 = 45 cm ==> 44.6 cm
- **Shell between coils:**
 - Bromberg: thickness = 10 cm ==> 10.9 cm
 - Wang: thickness ~ 35 cm ==> 34.7 cm
 - Williamson: thickness = 60 cm x 3/8 = 22.5 cm ==> 22.3 cm
- **Bucking cylinder behind strongback on small- R side:**
 - Bromberg: thickness = 27.5 cm ==> 29.9 cm
 - Wang: thickness ~ 85 cm ==> 84.2 cm
 - Williamson: thickness = 200 cm x 3/8 = 75 ==> 74.3 cm
- **Used Bromberg's values scaled by $B^2 R^2$**

Need to Revise Coil-Associated Thicknesses

- Sides need to be as thick or thicker than strongback *at some points* along the coil circumference!
- Radial forces only outward



D. Williamson, ORNL

Calculation of Coil-Associated Areas

- Strongback behind coils

— $\text{area}_{\text{back}} = \text{area}_{\text{coil}} \times r_{\text{mid,back}} / \langle a_{\text{coil}} \rangle$ where $\text{area}_{\text{coil}} = L_{\text{coil}} \times \text{width}_{\text{coil}}$,
 $L_{\text{coil}} = 90R$, $\text{width}_{\text{coil}} = (R/10.03 - 0.02)$, $\langle a_{\text{coil}} \rangle = 0.504R$
 $r_{\text{mid,back}} = \langle a_{\text{coil}} \rangle + \text{depth}_{\text{coil}}/2 + \text{thick}_{\text{sb}}/2$
 for $\langle R \rangle = 8.25$ m, $\text{area} = 263 \text{ m}^2$ vs $3(45 + 33.1) = 234 \text{ m}^2$ for D.W.

- Shell between coils (outboard)

— $\text{area}_{\text{shell}} = (1 - 0.326) \times 0.67 \times [\text{area}_{\text{coil winding surface}} - \text{area}_{\text{coil}}] \times$
 $r_{\text{mid,shell}} / \langle a_{\text{coil}} \rangle$ where $\text{area}_{\text{coil winding surface}} = 27R^2$,
 $r_{\text{mid,sb}} = \langle a_{\text{coil}} \rangle + \text{depth}_{\text{coil}}/2 + \text{thick}_{\text{sb}} - \text{thick}_{\text{shell}}/2$
 for $\langle R \rangle = 8.25$ m, $\text{area} = 913 \text{ m}^2$ vs $3(365.4) = 1096 \text{ m}^2$ for D.W.

- Bucking cylinder (inboard)

— $\text{area}_{\text{buck}} = 0.326 \times \text{area}_{\text{coil winding surface}} \times r_{\text{mid,buck}} / \langle a_{\text{coil}} \rangle$
 $r_{\text{mid,buck}} = \langle a_{\text{coil}} \rangle + \text{depth}_{\text{coil}}/2 + \text{thick}_{\text{buck}}/2$ (+ $\text{thick}_{\text{back}}??$)
 for $\langle R \rangle = 8.25$ m, $\text{area} = 765 \text{ m}^2$ vs $3(165.3) = 496 \text{ m}^2$ for D.W.

- Values depend on model for structure thicknesses;
area coverage fractions from D.Williamson's 3-D calcs

Component Volumes Summary (m³)

total modular coil volume	154.05	total shield + back wall volume	218.78
conductor pack	77.02	ferritic steel shield	160.85 2.313
rest winding pack	77.02	1st shield-only WC shield	6.01 1.705
total structure volume	404.35	shield-only back wall	1.69 1.825
bucking cylinder on inside	78.85	2nd shield-only WC shield	15.80 2.057
strongback behind coils	270.69	1st transition WC shield	5.08 1.955
outer shell between coils	54.81	trans shield back wall	3.74 2.015
		2nd transition WC shield	25.59 2.197
total FW, blanket, BW volume	398.891		
first wall	22.45 1.591	volume of manifolds	302.77
front full blanket	321.77 1.881	full-blanket manifold	286.91 2.598
front blanket back wall	34.35 2.177	transition manifold	15.86 2.442
second blanket	0.00 2.202		
transition blanket	20.32 1.765		
total vacuum vessel volume	299.68	volume of empty core	1778.51
full blanket vacuum vessel	259.13 2.933	volume of liquid metal in core	342.91
shield-only vacuum vessel	12.60 2.424		
transition vacuum vessel	27.95 2.689	volume of filled core	2121.42

r_{mid} (m) in blue



Composition

(Nominal Blanket/Shield and Shield-only zones)
(no divertor info)

<u>Component</u>	<u>Thickness</u>	<u>Coverage Fraction</u>	<u>Composition</u>
FW*	3.8 cm	100%	34% FS Structure 66% He Coolant
Blanket*	54.3 cm	85%#	79% LiPb (90% enriched Li) 7% SiC Inserts (95% d.f.) 6% FS Structure 8% He Coolant
Back Wall*	5 cm	100%	80% FS Structure 20% He Coolant
FS Shield	18 cm	85%	15% FS Structure 10% He Coolant 75% Borated Steel Filler
Manifolds	35 cm	85%	52% FS Structure 24% LiPb (90% enriched Li) 24% He Coolant ??% SiC Inserts ???
WC Shield-I* (shield-only zone)	17-21 cm	5%	88% WC Filler 5% FS Structure 7% He Coolant
WC Shield-II (shield-only zone)	38 cm	5%	15% FS Structure 10% He Coolant 75% WC Filler
VV	28 cm	100%	28% FS Structure 49% Water 23% Borated Steel Filler

* Replaceable component.

For blanket and divertor,



Composition (Transition Region)

<u>Component</u>	<u>Av. Thickness</u>	<u>Coverage Fraction</u>	<u>Composition</u>
FW*	3.8 cm		34% FS Structure 66% He Coolant
Blanket*	31 cm	10%	~79% LiPb (90% enriched Li) ~7% SiC Inserts ~6% FS Structure ~8% He Coolant
Back Wall*	5 cm		80% FS Structure 20% He Coolant
WC Shield-I*	7 cm	10%	88% WC Filler 5% FS Structure 7% He Coolant
WC Shield-II	28 cm	10%	15% FS Structure 10% He Coolant 75% WC Filler
Manifolds	17 cm	10%	52% FS Structure 24% LiPb (90% enriched Li) 24% He Coolant ?% SiC Inserts ???
VV	28 cm		28% FS Structure 49% Water 23% Borated Steel Filler

* Replaceable component.

Unit Cost and Mass Data for Systems Code

Designation	D1		
Description	LiPb Dual Coolant		
VV location	Internal to Coils	\$/kg	kg/m3
First Wall, Blanket	ODS/RA FS	\$103.00	7800
	Li17Pb83(90%Li6)	\$20.00	8897
	He		
Local Shield	RAFS	\$103.00	7800
	WC plates	\$30.00	15500
	He		
Shield	RAFS	\$78.00	7800
	Borated FS Plates	\$31.00	7800
	He		
Vac Vessel	RAFS	\$56.00	7800
	Borated FS Plates	\$31.00	7800
	H ₂ O		
		2004 \$	1992 \$

Other parameters

emultloc = 1.14

fwlife = 15 MW-yr/m²

thermeff = 0.42

fwth = 0.038

SiC inserts

\$415.20/kg, 3200 kg/m³

from option B chart

Component Thicknesses, Densities and Costs/m³

nom. blanket + FS shield region 85%

$$\text{blth1} = 0.542 \text{ m}$$

$$\text{blbw} = 0.05 \text{ m}$$

$$\text{blth2} = 0$$

$$\text{blgap} = 0$$

$$\text{FSshth} = 0.18 \text{ m}$$

$$\text{thman1} = 0.35 \text{ m}$$

$$\text{shvvgap} = 0.02 \text{ m}$$

$$\text{vvth1} = 0.28 \text{ m}$$

densities in tonnes/m³, cost in k\$/m³

$$\text{fwthden} = 7.8 \times 0.34 = 2.652 \text{ tonnes/m}^3$$

$$\text{blth1den} = 7.8 \times 0.06 + 15.5 \times 0.07 = 1.553 \text{ tonnes/m}^3$$

$$\text{blbwden} = 7.8 \times 0.8 = 6.24 \text{ tonnes/m}^3$$

$$\text{thmanden} = 7.8 \times 0.52 = 4.056 \text{ tonnes/m}^3$$

$$\text{FSshthden} = 7.8 \times 0.15 + 7.8 \times 0.75 = 7.02 \text{ tonnes/m}^3$$

$$\text{vvth1den} = 7.8 \times 0.28 + 7.8 \times 0.23 = 3.978 \text{ tonnes/m}^3$$

$$\text{fwthcpm3} = 7.8 \times 0.34 \times 103. = 222.376$$

$$\text{blth1cpm3} = 7.8 \times 0.06 \times 103. + 15.5 \times 0.07 \times 30. = 65.742$$

$$\text{blbwcpm3} = 7.8 \times 0.8 \times 103. = 523.24$$

$$\text{FSshthcpm3} = 7.8 \times 0.15 \times 78. + 7.8 \times 0.75 \times 31. = 222.694$$

$$\text{thmancpm3} = 7.8 \times 0.52 \times 78. = 257.555$$

$$\text{vvth1cpm3} = 7.8 \times 0.28 \times 56. + 7.8 \times 0.23 \times 31. = 177.918$$

transition region 10%

$$\text{blth3} = 0.31 \text{ m}$$

$$\text{WCshth3} = 0.07 \text{ m}$$

$$\text{WCshth4} = 0.28 \text{ m}$$

$$\text{thman2} = 0.35/2 = 0.175 \text{ m}$$

$$\text{WCshth3den} = 7.8 \times 0.05 + 15.5 \times 0.88 = 14.03 \text{ m}$$

$$\text{WCshth4den} = 7.8 \times 0.15 + 15.5 \times 0.75 = 12.975 \text{ m}$$

WC shield only region 5%

$$\text{WCshth1} = 0.19 \text{ m}$$

$$\text{shbw} = 0.05$$

$$\text{shgap} = 0$$

$$\text{WCshth2} = 0.38 \text{ m}$$

$$\text{vvth2} = 0.28 \text{ m}$$

$$\text{WCshth1den} = 7.8 \times 0.05 + 15.5 \times 0.88 = 14.03$$

$$\text{shbwden} = 7.8 \times 0.8 = 6.24$$

$$\text{WCshth2den} = 7.8 \times 0.15 + 15.5 \times 0.75 = 12.795$$

$$\text{vvth2den} = \text{vvth1den}$$

$$\begin{aligned} \text{WCshth1cpm3} &= 7.8 \times 0.05 \times 103. + 15.5 \times 0.88 \times 30. \\ &= 449.37 \end{aligned}$$


$$\text{shbwcpm3} = 7.8 \times 0.8 \times 103. = 642.72$$

$$\begin{aligned} \text{WCshth2cpm3} &= 7.8 \times 0.15 \times 103. + 15.5 \times 0.75 \times 30 = \\ &469.26 \end{aligned}$$

$$\text{vvth2cpm3} = \text{vvth1cpm3}$$

Calculation of Coil-Related Costs (Bromberg)

- **Conductor cost varies rapidly with $B_{\max}$**
 - * $\text{cost} = L_{\text{coil}} I_{\text{coil}} f(B_{\max}) = k_1 k_2 B_{\text{axis}} \langle R \rangle^2 f(B_{\max})$
 - * could be reduced factor of 3 by developing advanced manufacturing and increased billet size?
- **Cost of winding coil: mass of conductor x \$80/kg**
 - * $\text{cost} = 80 \rho L_{\text{coil}} I_{\text{coil}} / j = k_1 k_2 B_{\text{axis}} \langle R \rangle^2 [80 \rho / j(B_{\max})]$
- **Coil structure cost = volume x 7800 kg/m³ x \$56/kg = $k_3 \langle R \rangle^2$**



Component Mass Summary (tonnes)

total modular coil mass ~~847.27~~

conductor pack 423.64

~~rest winding pack 423.64~~

total VF coils 0.00

divertor coils 0.00

total structure mass 3153.91

bucking cylinder 614.99

strongback 2111.42

outer shell 427.49

total blanket, first, back wall 805.16

first wall 59.54

front full blanket 499.71

front blanket back 214.37

second blanket 0.00

transition blanket 31.55

total vacuum vessel mass 1192.13

full blanket vacuum vessel 1030.81

shield-only vacuum vessel 50.12

transition vacuum vessel 111.20

shield and back wall masses 1825.06

ferritic steel shield 1129.16

1st shield-only WC shield 84.38

shield-only back wall 10.57

2nd shield-only WC shield 202.17

1st transition WC shield 71.29

trans shield back wall 23.34

2nd transition WC shield 327.49

mass of manifolds 1228.05

full blanket manifold 1163.71

transition manifold 64.34

total nuclear island 9051.58

mass of liquid metal coolant 3050.89

mass of nuclear island + coolant 12,102.47

Comparing Masses with AT, RS & SPPS

Mass (tonnes)	CS	AT	RS	SPPS
FW/Blanket/BW	805	255	585	251
Shield, BW, man.	3053	882	4235	9453
Coils	847	1525	3280	4191
Structure	3154	----	1627	5365
Vacuum Vessel	1192	1415	1357	2171
Fusion Power Core	9,052	5,226	12,679	21,430
LM Coolant	3,051	5,269	223	175
FPC + Coolant	12,102	10,495	12,902	21,605

Component Cost Summary (1992 \$)

total modular coil cost	73.27
conductor pack	60.21
rest winding pack	13.80
total VF coils	0.00
divertor coils	0.00

total structure cost	143.79
bucking cylinder	28.04
strongback	96.26
outer shell	19.49

total blanket, first, back wall	45.46
first wall	4.99
front full blanket	21.15
front blanket back	17.98
second blanket	0.00
transition blanket	1.34

total vacuum vessel cost	43.41
full blanket vacuum vessel	37.53
shield-only vacuum vessel	1.82
transition vacuum vessel	4.05

shield and back wall costs	58.41
ferritic steel shield	35.70
1st shield-only WC shield	2.20
shield-only back wall	0.89
2nd shield-only WC shield	6.03
1st transition WC shield	1.87
trans shield back wall	1.95
2nd transition WC shield	9.78

cost of manifolds	77.98
full blanket manifold	73.90
transition manifold	4.09

total nuclear island	299.27
-----------------------------	---------------

cost of liquid metal coolant	126.68
-------------------------------------	---------------

cost of nuclear island + coolant	425.94
---	---------------

Cost Accounts (1992 M\$)

Cost 20 (Land) = 10.439

Cost 21.1 (site improvements) = 18.440
 Cost 21.2 (reactor building) = 127.615
 Cost 21.3 (turbine building) = 31.748
 Cost 21.4 (cooling system) = 7.903
 Cost 21.5 (PS building) = 9.988
 Cost 21.6 (misc. buildings) = 112.591
 Cost 21.7 (vent. stack) = 1.973

Cost 21 (Structure) = 325.421

Cost 22.1.1.1 (FW) 4.992
 Cost 22.1.1.3 (BL+ BW) 40.465
 Cost 22.1.1 (BI, BW & 1st wall) 45.458
 Cost 22.1.2 (Shield + BW) = 136.397
 Cost 22.1.3 mod. coils 74.004
 Cost 22.1.3 VF coils 0.000
 Cost 22.1.3 div = 0.000
 Cost 22.1.3 structure = 143.788
 Cost 22.1.3 (total coils) = 74.0041

Cost 22.1.4 (Heating) = 53.662
 Cost 22.1.5 (Primary Str.) = 143.788
 Cost 22.1.6 (Vac. Sys.) = 109.232
 Cost 22.1.7 (Power Sup.) = 55.322
 Cost 22.1.8 (Imp. Control) = 5.528
 Cost 22.1.9 (Dir. Ener. Conv.) 0.000
 Cost 22.1.10 (ECH) = 0.000
Cost 22.1 (Core) = 623.391

Cost 22.2.1 prim. coolant 196.978
 Cost 22.2.2 interm coolant 0.000
 Cost 22.2.3 sec. coolant 0.000
Cost 22.2 (Heat transport) = 196.978

Cost 22.3 aux. cooling 2.699
 Cost 22.4 rad. waste = 4.810
 Cost 22.5.1 fuel inj. = 11.411
 Cost 22.5.2 fuel proc. 13.395
 Cost 22.5.3 fuel storag 5.706
 Cost 22.5.4 atm T recov 2.707
 Cost 22.5.5 H2O T recov 5.706
 Cost 22.5.6 BL T recov. 5.706
 Cost 22.5 fuel hand. = 44.630
 Cost 22.6 other pl eq = 43.882
 Cost 22.7 I&C = 35.975

Cost 22 (Reactor Plant) = 971.413

Cost 23.1 turb.-gen. = 0.000
 Cost 23.2 misc turb-gen 0.000
 Cost 23.3 heat reject. 41.508
 Cost 23.4 condens. sys 0.000
 Cost 23.5 feed heating 0.000
 Cost 23.6 other turb eq 0.000
 Cost 23.7 I&C equip. = 0.000
Cost 23 (Turbine Plant) = 262.540

Cost 24.1 = 0.000
 Cost 24.2 = 0.000
 Cost 24.3 = 0.000
 Cost 24.4 = 0.000
 Cost 24.5 = 0.000
 Cost 24.6 = 0.000
 Cost 24.7 = 0.000

Cost 24 (Electric Plant) = 103.624

Cost 25.1 = 0.000
 Cost 25.2 = 0.000
 Cost 25.3 = 0.000
 Cost 25.4 = 0.000

Cost 25 (Misc. Plant Eq.) = 51.916

Cost 26.4 other mater. 124.097
Cost 26 (Spec. Matls.) = 126.672

Comparison of General Plant Costs (1992 \$)

Parameter	CS	AT	RS	SPPS
$\langle R \rangle$, m	6.93	5.20	5.52	13.95
$\langle B_{\text{axis}} \rangle$, T	6.28	5.86	7.98	4.94
$\langle \beta \rangle$, %	5.0	9.2	5.0	5.0
FPC Mass, tonnes	9,052	5,226	12,679	21,430
CoE, mills/kW _e h (1992 \$)	55.7	56.6	75.7	74.9
90 Total Direct Cost (M\$)	1902	1757	2189	2261
20 Land	10.4	10.6	10.4	10.4
21 Structure	325.4	335.5	331.0	332.5
<i>22 Reactor Plant Equip.</i>	<i>971.4</i>	<i>900.3</i>	<i>1386</i>	<i>1487</i>
23 Turbine Plant Equip.	262.5	243.0	284.4	254.0
24 Electric Plant Equip.	103.6	110.3	110.6	103.6
25 Misc. Plant Equip.	51.9	50.1	56.2	51.9
26 Special Materials	126.7	83.8	11.1	21.1

Heat Rejection System

+23.3

22+26 Reactor Plant + LM

1098

984.1

1397

1508

- Only Reactor Plant Equip. contains stellarator costs

Comparison of General Plant Costs (1992 \$)

Cost (M\$)	CS	AT	RS	SPPS
21 Structure	325.4	335.5	331.0	332.5
21.2 reactor building	127.6	n. a.	n. a.	141.6
21.6 misc. buildings	112.6	n. a.	n. a.	112.7
22 Reactor Plant Equip.	971.4	900.3	1386	1487
<i>22.1 reactor equipment</i>	<i>623.4</i>	<i>519.9</i>	<i>966.4</i>	<i>1115</i>
22.2 heat transport	197.0	209.9	258.3	217.8

- While the reactor equipment is the largest cost component, the costs of structure (buildings) and heat transport are also large

Comparing Costs with AT, RS & SPPS

Cost (M\$)	CS	AT	RS	SPPS
22.1 Reactor Equipment	623.4	519.9	966.4	1115
Cost of stellarator parts	255.9 41%	274.9 53%	516.3 53%	750.9 67%
22.1.1 blanket & 1 st wall	45.5	67.9	74.3	71.5
22.1.2 shield, BW, man.	136.4	73.3	168.0	289.8
22.1.3 coils	74.0	133.7	274.0	389.6
22.1.4 heating	53.7	41.0	164.2	54.2
22.1.5 primary structure	143.8	29.8	53.4	152.9
22.1.6 vacuum systems	109.2	109.2	159.2	85.4
22.1.7 power supplies	55.3	56.1	55.3	55.3
22.1.8 impurity control	5.5	4.5	13.6	12.0
22.1.10 ECH startup	0	4.4	4.3	4.3

Cost Element Breakdown (1992 M\$)

	NCSX-ARE	ARIES-RS	ARIES-AT	
Cost 20 (Land)	10.439	10.438	10.589	constant
Cost 21.1 (site improvements)	18.440			constant
Cost 21.2 (reactor building)	127.615			$\sim V_{\text{reactor building}}^{0.62}$
Cost 21.3 (turbine building)	31.748			$\sim [(\eta_{\text{th}} P_{\text{th}})^{0.75} + \text{constant}]$
Cost 21.4 (cooling system)	7.903			$\sim (\eta_{\text{th}} P_{\text{th}})^{0.3}$
Cost 21.5 (PS building)	9.988			constant
Cost 21.6 (misc. buildings)	112.591			constant
Cost 21.7 (vent. stack)	1.973			constant
Cost 21 (Structure)	325.421	331.027	335.497	
Net thermal efficiency η_{th}	42%	XX%	XX%	
Global energy multiplier (gloem)	XXXX	XXXX	XXXX	
$P_{\text{th}} = P_{\text{n}} \times \text{gloem} + P_{\alpha}$	2610.2	2618.6	1982.4	
Gross Electric Power (MW)	1054.9	1204.5	1169.6	

Cost Element Breakdown (1992 M\$)

	NCSX-ARE	ARIES-RS	ARIES-AT	
Cost 22.1.1.1 (FW)	4.992			
Cost 22.1.1.3 (BL + BW)	40.465			
Cost 22.1.1 (BI/BW & 1st wl.)	45.458	74.263	67.851	
Cost 22.1.2 (Sh/BW/man)	136.397	168.010	73.265	
Cost 22.1.3 mod coils	74.004			
Cost 22.1.3 VF coils	0.000			
Cost 22.1.3 divertor	0.000			
Cost 22.1.3 (coils + str)	198.160	274.014	133.724	
Cost 22.1.4 (Heating)	53.662	164.211	40.984	constant 20 MW
Cost 22.1.5 (Primary Str.)	143.788	53.449	29.785	coil winding surface
Cost 22.1.6 (Vac. Sys.)	109.232	159.226	109.231	vacuum vessel only
Cost 22.1.7 (Power Sup.)	55.322	55.322	56.119	constant
Cost 22.1.8 (Imp. Control)	55.278	13.610	4.528	~ divertor area
Cost 22.1.9 (Dir. Ener. Conv.)	0			
Cost 22.1.10 (ECH breakdown)	0	4.334	4.396	
Cost 22.1 (Core) =	623.391	966.439	519.883	

Cost Element Breakdown

	NCSX-ARE	ARIES-RS	ARIES-AT	
Cost 22.2.1 primary coolant	196.978			$\sim P_{th}^{0.55}$
Cost 22.2.2 intermediate coolant	0.000			
Cost 22.2.3 secondary coolant	0.000			
Cost 22.2 (Heat transport)	196.978	258.267	209.947	
Cost 22.3 aux. cooling	2.699			$\sim P_{th}$
Cost 22.4 rad. waste	4.810			$\sim P_{th}$
Cost 22.5.1 fuel injection	11.411			constant
Cost 22.5.2 fuel processing	13.395			constant
Cost 22.5.3 fuel storage	5.706			constant
Cost 22.5.4 atm T recover.	2.707			constant
Cost 22.5.5 H ₂ O T recover.	5.706			constant
Cost 22.5.6 BL T recover.	5.706			constant
Cost 22.5 fuel handling	44.630			constant
Cost 22.6 other plant equip	43.882			$\sim P_{th}$
Cost 22.7 I&C	35.975			constant
Cost 22 (Reactor Plant)	971.413	1385.691	900.282	

Cost Element Breakdown

	NCSX-ARE	ARIES-RS	ARIES-AT	
Cost 23 (Turbine Plant)	262.540	284.446	243.034	$\sim[(\eta_{th} P_{th})^{0.83} + \text{constant}]$
23.3/26 heat reject.	41.508		23.317	$\sim[P_{th} - (\eta_{th} P_{th})]$
Cost 24 (Electric Plant)	103.624	110.604	110.326	$\sim(\eta_{th} P_{th})^{0.49}$
Cost 25 (Misc. Plant Eq.)	51.916	56.165	50.139	$\sim(\eta_{th} P_{th})^{0.59}$
26.4 other materials	192.011			$\sim V_{LiPb}$
Cost 26/7 (Spec. Matls.)	126.672	11.073	83.766	
Cost 90 (Direct Cost)	1843.069	2189.445	1756.949	

Total Costs (1992 M\$) and COE

Cost 90	Total Dir Cost	1843.069	51.827%	Capital return	46.136
Cost 91	Construction	221.168	6.219	[40-47,51] O&M costs	8.177
Cost 92	Home office	95.840	2.695	[50] FW/BL/WCSHI/BW replace	0.883
Cost 93	Field office	110.584	3.110	Decomissioning allowance	0.500
Cost 94	Owner's costs	340.600	9.578	[02] Deuterium fuel	0.030
Cost 96	Proj. Contingency	440.678	12.392	Cost of Electricity, COE	55.726 in 1992 \$
Cost 97	Constr Interest	504.264	14.180	cost of replacement blanket + shield	
Cost 98	Constr Escalation	0.000	0.000	52.360	
Cost 99	Total Capital Cost	3556.203	100.000	number of blanket + shield replacements	
				14.35	
[90]	Unit direct cost, UDC	1843.069			
[94]	Unit base cost, UBC	3051.939			
[99]	Unit total cost, UTC	3556.203			

CoE Components for CS, AT, RS & SPPS

mills/kW _e h	CS	AT	RS	SPPS
CoE (in 1992 \$)	55.73	56.61	75.66	74.92
Cap. Return	46.14	43.95	61.34	63.34
O & M	8.18	8.34	9.16	9.16
FW/BI replace.	0.88	3.79	4.63	1.90
Decomm.	0.50	0.50	0.50	0.50
Fuel costs	0.03	0.03	0.03	0.03

- Largest CoE component is Capital Return
- Cap. Return $\propto$ Total Cap. Cost $\propto$ Total Direct Cost