



Assessment of Power Core Parameters and Related Costs (Part-II)

L. El-Guebaly

Fusion Technology Institute
UW - Madison

With input from:

R. Miller (Decysive Systems), J. Lyon (ORNL),
L. Waganer (Boeing), R. Raffray, S. Malang (UCSD)

ARIES-CS Project Meeting

January 23, 2006

UCSD

Contents

- Revised costing accounts (in 2004\$):
 - # 21: Structures & Site Facilities
 - # 21.2: Reactor Building
 - # 22: Reactor Plant Equipment
 - # 22.1.5 Primary Structure
 - # 22.2 Main Heat Transfer & Transport System
 - # 23: Turbine Plant Equipment
 - # 26: Heat Rejection System
- Impact of dual-coolant on radial build and COE.
- References:
 - Documented costing algorithms: SPPS report, Section 3.2.3, Page 3-23.
 - Latest costing algorithms: R. Miller (Decysive Systems), private communications.



Account # 21.2 (Reactor Building)

$$\text{Cost (2004 M\$)} = [77.1 (V_{\text{RB}}^{\#} / 80,000)^{0.62} \times \text{LSA Factor}] \times 1.256^*$$

$$\text{ARIES-CS } V_{\text{RB}} \sim 2.1 \times 10^5 \text{ m}^3. \text{ TBD.}$$

ARIES-

LSA

RS

AT

CS

2

1

2

21.2 Reactor Bldg (M\$- 2004\$)

~ 160

~ 100

~ 160

Torus volume = 4-5% of building free volume (V_{RB}).

* 2004\$ = 1992\$ x 1.256, per Les.



Account # 22.1.5 (Primary Structure)

$$\text{Cost (2004 M\$)} = [\text{volume} \times \text{steel density (7.8 gm/cm}^3\text{)} \times \text{vol. fract. (0.95)} \\ \times \text{unit cost (~25 \$/kg)} \times \text{LSA Factor}] \times 1.256$$

$$\text{Volume} = 18.4\% \text{ FPC volume}$$

$$\text{FPC volume} = \text{actual volume of FW + blanket + divertor + shield + VV} \\ + \text{winding pack + coil structure (including bucking structure)}$$

ARIES-

LSA

21.1.5 Primary Str. (M\$- 2004\$)

RS

2

67

AT

1

34

CS

2

~ 80



Account # 22.2

(Main Heat Transfer & Transport System)

P_{th} and power split between He and LiPb

3 sub-accounts (in 2004 M\$):

22.2.1 for **Primary** coolant (LiPb or He): $234 (P_{th} / 3500)^{0.55} \times 1.256$

22.2.2 for **Intermediate** coolant = 0

22.2.2 for **Secondary** coolant (He): $75 (P_{th} / 3500)^{0.55} \times 1.256$

↪ **Highly pure He (no O, no N)**

For **Dual-coolant system**, modify **Primary** coolant account:

$$234 [(P_{th} \times \text{F-He} / 3500)^{0.55} + (P_{th} \times \text{F-LiPb} / 3500)^{0.55}] \times 1.256$$


where **F-He** power fraction carried by He (= 42%. To be updated),
F-LiPb power fraction carried by LiPb (= 58%. To be updated).

ARIES-CS Coolant Routing

(R. Raffray - 11/05 ARIES Meeting)

4 HXs?

Impact on Account 22.2?





Account # 22.2 (Cont.) (Main Heat Transfer & Transport System)

Per Siegfried:

- LiPb requires Nb HX
- Nb HX costs 0.012 M\$ per (P_{th} x F-LiPb).

For ARIES-CS, Account 22.2 (in 2004 M\$)=

$$\begin{aligned} & [234 (P_{th} \times F\text{-He} / 3500)^{0.55} \\ & + 234 (P_{th} \times F\text{-LiPb} / 3500)^{0.55} + 0.01 (P_{th} \times F\text{-LiPb}) \\ & + 75 (P_{th} / 3500)^{0.55}] \times 1.256 \end{aligned}$$

Impact of 4 HXs on Account 22.2 should be determined.



Account # 22.2 (Cont.) (Main Heat Transfer & Transport System)

$$\text{Account 22.2 (2004 M\$): } [234 ((P_{th} \times F\text{-He} / 3500)^{0.55} + (P_{th} \times F\text{-LiPb} / 3500)^{0.55}) + 0.01 (P_{th} \times F\text{-LiPb}) + 75 (P_{th} / 3500)^{0.55}] \times 1.256$$

ARIES-	RS	ST	AT	CS
LSA	2	2	1	2
Single or dual-coolant?	Single	Dual	Single	Dual
He:LiPb power	--	49:51	---	42:58
P_{th} (MW _{th})	2619	3373	1968	~ 2610
Cost (M\$ - 2004\$)	293+30*	450 (330 for single coolant) with intermediate loop)	158	~ 440 (~290 for single coolant with intermediate loop)

* For V liner in outer loop.



ARIES-CS Recirculating Power

MW_e

Miscellaneous Power

~ 50

He Pumping Power

$28 + 97$ (for 5 MW/m^2 peak $\square$)
div. + Blkt

Cryogenic Power

~ 5

Total

~ 180

$\square P_{\text{Gross}} \sim 1180 \text{ MW}_e$



Account # 23

(Turbine Plant Equipment)

Account 23 (2004 M\$): $240.3 (P_{\text{Gross}} / 1200)^{0.83} \times 1.02^{\#} \times 1.256$

Single coolant

Account 23 (2004 M\$): $240.3 [(P_{\text{Gross}} \text{ F-He} / 1200)^{0.83} + (P_{\text{Gross}} \text{ F-LiPb} / 1200)^{0.83}] \times 1.02^{\#} \times 1.256$

ARIES-ST
dual coolant
□ Separate
turbines

Does ARIES-ST formula apply to ARIES-CS?

ARIES-	RS	ST	AT	CS
Single or dual-coolant	Single	Dual	Single	Dual
He:LiPb power	--	49:51	---	42:58
P_{Gross} (MW _e)	1205	1518	1161	~1180
Cost (M\$ - 2004\$)	309 + 48*	426	303	~ 340 ??? (~ 300 for single coolant)

For spare parts.

* For Heat Rejection System.



Account # 26

(Heat Rejection System)

Account 26 (2004 M\$): $61.4 [(P_{th} - P_{Gross}) / 2300] \times 1.02^{\#} \times 1.256$

ARIES-

RS

ST

AT

CS

P_{th} (MW_{th})

2619

3373

1968

~ 2610

P_{Gross} (MW_e)

1205

1518

1161

~1180

Cost (M\$ - 2004\$)

48

74*

29

~ 50

For spare parts.

* Includes waste heat from resistive coils.



Impact of Dual-Coolant on Radial Build and COE

Zone	Uniform Blanket	Non-uniform Blanket
FW/B/S/Mnflld Thick. (cm)	130	70
He Thickness (cm)	20 (15%)	9 (13%)

Impact on:

Major radius	0.5 - 1 m	☐	↑	COE
Increase in FPC volume/mass	10-20%	☐	↑	COE
He pumping power	~100 MW _e	☐	↑	COE
Main Heat Transp. & Transf. Systems	~150 M\$	☐	↑	COE
Turbine Plant Equipment	~40 M\$	☐	↑	COE
☐ _{th}	~ same for dual or single coolant			

**Dual-coolant helps solve MHD problems
but increases COE by ~ 10 mills/kWh**

Is advanced LiPb/SiC system more suitable for ARIES-CS?