

Systems Code Status

J. F. Lyon, ORNL

ARIES Meeting

June 14, 2006

Topics

- Systems code changes since April meeting
 - requested revisions and additions
- Parameters for reference ARE case
 - comparison with parameters for April case
- Effect of parameter variations
- Work in progress, further refinements needed

Les Waganer's Action Items

1. Provide Neutron Source Profile to Mau and Wilson
L-P Ku & I provided code lines and data to Paul Wilson
 - calculation of neutron production rate on a flux surface
 - data file for VMEC coefficients $r_{m,n}(\psi, \theta, \phi)$, $z_{m,n}(\psi, \theta, \phi)$
 - conversion from ψ, θ, ϕ VMEC coordinates to x, y, z
2. Check Delta-Min Used in Code -- revised
3. Check Power to the Divertor - should include alpha power (~ 41 MW extra) -- was OK, has always been included


Code Changes Since Last Meeting -- 1

- (1) Lower neutron flux in the divertor region was used to revise the neutron and radiation flux to the divertor
- calculation that gave 1.52 for peak/average ratio gave 0.737 for the minimum/average ratio (= 1.91 MW/m² for ARE ref. case).
 - this reduces the *effective area of the divertor* from 15% to 11%
- (2) 75% of particle power crossing plasma surface is radiated in the scrapeoff layer (SOL) and divertor vicinity; 25% hits the divertor plate as charged particle power
- of the power radiated in SOL, 1/2 is radiated to the wall and divertor, 1/2 in the vicinity of the divertor
 - of the power radiated in the vicinity of the divertor, 1/2 goes to the divertor and 1/2 to the wall

$$\begin{aligned} p_{\text{divert}} = & p_{\text{dt}} * f_{\text{loss}} + p_{\text{rsum}} * \text{divfract} * 0.737 + p_{\text{cond}} * (1. - f_{\text{SOLrad}}) \\ & + p_{\text{cond}} * f_{\text{SOLrad}} * (0.5 * 0.5 + 0.5 * \text{divfract} * 0.737) \end{aligned}$$

$$\begin{aligned} p_{\text{wall}} = & p_{\text{rsum}} * (1. - \text{divfract} * 0.737) \\ & + p_{\text{cond}} * f_{\text{SOLrad}} * (0.5 * 0.5 + 0.5 * (1. - \text{divfract} * 0.737)) \end{aligned}$$


Power Fractions for Reference ARE Case



Reducing Power & Peak Load on Divertor


$$\begin{aligned} f_{\text{div}} = P_{\text{div}}/P_{\alpha} &= f_{\text{loss}} + f_{\text{part}}*(1 - f_{\text{SOLrad}}) + f_{\text{rad,core}}*f_{\text{div area}}*0.737 \\ &\quad + f_{\text{part}}*f_{\text{SOLrad}}*(0.5*f_{\text{div area}}*0.737 + 0.5*0.5) \\ &= 0.05 + 0.05 + 0.08 + 0.05 = 0.23 \end{aligned}$$

- Reduced power to divertor by reducing f_{loss} to 5% (vs 10% before), radiating 75% from core and 75% of the particle power in the SOL
 - this also reduced peaked (particle) power component
 - 0.56 MW/m² radiated power flux on divertor
 - 0.43 MW/m² ave. particle power flux on divertor
 - ⇒ allows 9.44 MW/m² particle power on divertor & peaking factor of 14.6!



Code Changes Since Last Meeting -- 2

- (3) Put 90% of electrical (He) pump power back into the thermal power
 - decreases P_{fusion} required from 2457 MW to 2355 MW
- (4) changed inter-coil shell thickness from 35 cm to 20 cm,
scaled Xueren's penetrations by R^2 ,
changed strongback thickness from 65 cm to 28 cm
 - decreases coil structure from 5730 t to 3420 t
- (5) Changed availability from 76% to 85%
- (6) Changed cost of coil structure from \$56/kg to \$20/kg (2004 \$)
- (7) R_{min} changed to be consistent with Laila's value ($\Delta = 5$ cm)
- (8) parametric dependence of α -particle loss fraction on R , B , n and T from Long-Poe's calculation of α -particle loss vs $v^* \sim nR/T^2$



Consequences of Fixed α -Particle Loss Rate

- (1) the fraction of the power in core radiation was targeted to be $\geq 75\%$ and the α -particle loss rate was targeted to be $\leq 5\%$. However, the code always gave these two limits.
- (2) It was not possible to reduce the α -particle loss rate to 5% with the core radiation fraction = 75% for $R = 7.5$ m. As the α -particle loss rate decreases below 10%, $R_{\min}$ increases above 7.5 m.
 - $B_{\max}$ increases so the current density in the coil pack must decrease and the radial depth of the coil pack increase.
- (3) As the α -particle loss rate decreases: the coil pack thickness, B_{axis} , $B_{\max}$, n and n_{DT}/n_e increase; T , %He and % Fe decrease.
 - below 4.5% α -particle losses, n is above twice the Sudo limit, which depends on B_{axis} and R .
 - nR/T^2 determines the α -particle loss rate; the code selects the lowest value that gives the limiting value.
 - nT/B_{axis}^2 is constrained for a fixed β value.
 - $n^2 f(T)$ determines the power radiated from the core, and $\sim n^2 T^2$ and fuel dilution determine the fusion power.


Code Changes Since Last Meeting -- 3

- (9) Added 1 cm to the coil-coil distance calculation
- (10) Scaled TBR and blanket thickness linearly between $R = 7.5$ -8 m rather than polynomial fit over a larger R range that did not give exactly Laila's value at $R = 7.5$ m
- (11) Changed A_{coil} (A_{Δ}) from 5.89 to 5.9385 for the ARE case
- (12) Changed EOL fluence from 15 to 15.7 Mwy/m² & blanket energy mult. From 1.16 to 1.155
- (13) $V_{\text{RB}} = 1.3 \times 10^5 \text{ m}^3 \times 1.3$ & cost (2004 \$) = $(33 + 0.00025V_{\text{RB}}) \times \text{LSA}$
 - 21.2: \$151M $\Rightarrow$ \$67.7M
- (14) Used ARIES-AT costing for plasma heating to ignition
 - 22.1.4: \$65.9M $\Rightarrow$ \$28.6M

Code Changes Since Last Meeting -- 4


- (15) Added more diagnostic output for divertor power and checking
- (16) Added new input variables: % power radiated in the scrapeoff and divertor regions; an extra gap space
- (17) Added new constraints to avoid negative power components and an undesired divertor solution:
 - an upper limit on the calculated α -particle loss fraction
 - a lower limit on the conduction power
 - a target value for R

$\langle R \rangle = 7.75$ m chosen to Give Margins on ${}^6\text{Li}$ % for TBR and $R_{\min}$ constraint



Not possible to set $R = 7.5$ m or 7.75 m -- always results in an over-constrained problem; the only way left to minimize the CoE is the value of B_{axis} , but there are too many conflicting constraints.

However, setting the value for $p_{n, \text{wall}}$ that gives $R = 7.75$ m worked



Consequences of Parameter Changes

(1) On divertor power load

- α -particle loss rate reduced from 10% to 5%
- effective divertor area reduced by 26% (from 15% to 11%)
- radiated 75% of particle power in SOL (52% to wall)
- net effect: P_{div} was 178 MW, now 108 MW
particle power was 123 MW, now 47.2 MW

(2) On cost of coil structure

- changed inter-coil shell thickness from 35 cm to 20 cm
- changed strongback thickness from 65 cm to 28 cm
⇒ decreased coil structure from 5730 t to 3420 t
- changed cost of coil structure from \$56/kg to \$20/kg (2004 \$)
⇒ decreased coil structure cost from \$321M to \$68M

(3) On COE


- from 98 mills/kWhr to 79 mills/kWhr in 2004 \$
- from 78 mills/kWhr to 63 mills/kWhr in 1992 \$

Reference vs April ARE Case


- $P_{\text{rad,core}}/P_{\alpha} = 75\%$

	June	April		June	April
$\langle R \rangle$ (m)	7.75	7.75	R/R_{min}	1.010	1.000
$\langle B_{\text{axis}} \rangle$ (T)	5.70	5.41	COE	79.0	98.3
$\langle n \rangle 10^{20} \text{m}^{-3}$	3.58	2.11	% P_{rad}	75.0	75.0
$\langle T \rangle$ (keV)	5.73	8.88	TBR	1.115	1.128
H-ISS95	1.48	1.83	τ_E (s)	0.96	0.88
$f_{\alpha,\text{loss}}$ %	5	10	$f_{\text{rad,SOL}}$ %	75	0
% Fe	0.008	0.062	P_{rad} (MW)	354	368
$\rho_{n,\text{max}}$ MW/m ²	3.95	4.11	P_H (MW)	240	141
$n/2n_{\text{Sudo}}$	0.94	0.57	P_{Fe} (MW)	113	225
$j_{\text{SC}}/j_{\text{max}}$	1.00	1.00	P_{cond} (MW)	94.4	73.6
B_{max} (T)	15.08	14.71	P_{div} (MW)	108	178
P_{fusion} (MW)	2364	2457	P_{wall} (MW)	364	313

Power Flows (MW) for Reference ARE Case




Variation With Radiated Power Fraction



Sensitivity to $\langle\beta\rangle$ Limit

- Constraints met for $\langle\beta\rangle < 6\%$



Items in Progress

1. Estimate COE for full blanket coverage as a reference point to justify complexity of a shield only zone
 - $\langle R \rangle = 9.81$ m (vs 7.75 m) close to meeting most constraints: ignition margin = 1.02, $P_{\text{electric}} = 984$ MW) but exceed others (j_{SC})
 - COE = 89.5 vs 79.0 mills/kWhr (2004 \$)
2. Generate parameters for MHH2 (K14LA) configuration
 - requires completion of full blanket case convergence

Further Additions, Refinements

Later this summer

- Revise replacement cost, coverage fractions (32% vs 28%)
- Add pumping costs (input from Farrokh) to 22.1.6 account (VV, Cry.)
- Generate parameters for SNS (KJC167) configuration
- Generate parameters for advanced LiPb/SiC design with 58% thermal conversion efficiency (get data from Laila).
- Near end of study, vary P_{electric} up to 1.5 GW or more
- Near end of study, look at NbTi at higher β .
- Calculation/comparison with HSR parameters

Still Needed

- Add VF or control coils to design
- Revision of manifold design?
- Better calculation of $B_{\text{max}} / \langle B_{\text{axis}} \rangle$?
- Additional divertor costs?
- Geometry for field period maintenance?

Summary

- Addressed most of the revisions and additions requested at April meeting
- Added new features to systems code
- Developed reference ARE case
- Studied effect of parameter variations
- Studied other cases
- Work in progress, refinements needed